



## Difference Between Bw and Cw Cable Glands

<b>Feature</b>	<b>BW Cable Glands</b>	<b>CW Cable Glands</b>
Construction	Two-part construction	Single-piece construction
Suitable for	Steel wire armoured (SWA) cables	Unarmoured and armoured cables
Sealing mechanism	Compression seal and separate locking ring	Compression seal and integral armour lock
Vibration resistance	Better, due to separate locking ring	Slightly lower, but still effective
Ease of installation	Slightly more complex	Easier and faster
Applications	Suitable for SWA cable applications with high vibration	Versatile and used in many applications